

Township of West Goshen  
Fire Marshal's Office

**Commercial Kitchen Systems Plan  
Submission Requirements**

Commercial Kitchen Hood Mechanical and Suppression Systems shall be designed and installed in accordance with the following codes which are enforced in West Goshen Township:

- 2009 International Building Code
- 2009 International Fire Code
- 2009 International Mechanical Code
- NFPA 17A, 2002 edition

Construction documents for kitchen hood systems shall be submitted for review and approval prior to system installation. Construction document shall include, but not be limited to, all of the following:

- Plans must include exact hood, duct, pipe, and appliance dimensions.
- Plans shall show the job name and complete address (including suite number).
- Catalog cut sheets must be provided for all nozzles and equipment to be used.
- The tank size and flow point count must be noted on the plans.
- All plans shall have the contractor's name, address and phone number.
- Pre-engineered automatic dry and wet chemical extinguishing systems shall be tested in accordance with UL 300 and listed and labeled for the intended application.

All plans shall be signed and sealed by either a Fire Protection Engineer or the system designer shall be certified to a minimum of NICET Level III. No exceptions.

**Two sets of plans shall be submitted to the Fire Marshal's Office.**